



AWBERC FIRE ALARM SYSTEM

UPGRADE FOR ADA COMPLIANCE PROJECT

26 WEST MARTIN LUTHER KING DRIVE, CINCINNATI, OHIO 45268

U.S. ENVIRONMENTAL PROTECTION AGENCY
FACILITIES MANAGEMENT AND SERVICES DIVISION

CINCINNATI, OHIO 300 WEST FOURTH STREET CINCINNATI, OHIO 45202 PHONE: (513) 721-0600 FAX: (513) 721-0611

- DETAILS

E1.7

ELECTRICAL CONTRACTOR SHALL EXTEND CONDUIT AND WIRING FROM TRANSPONDER TO EACH ELEVATOR CONTROLLER AND TERMINATE PER ELEVATOR MANUFACTURER REQUIREMENTS. COORDINATE LOCATION OF CIRCUITS WITH ELEVATOR MAINTENANCE CONTRACTOR. ELEVATOR MAINTENANCE CONTRACTOR SHALL MAKE FINAL CONNECTION TO ELEVATOR TRAVEL CABLE. ELECTRICAL CONTRACTOR SHALL INSTALL SPEAKER IN ELEVATOR CAB AND MAKE CONNECTION TO TRAVEL CABLE IN ELEVATOR CAB. ELEVATOR MAINTENANCE CONTRACTOR WORK TO BE INCLUDED IN ELECTRICAL CONTRACTOR PRICE.

SPECIFIC NOTE

GENERAL NOTES

A. SEE FLOOR PLANS FOR db RATING, CA LOCATION, ETC.

B. AS REQUIRED, INSTALL WELDED RING S OCCUR, AT THE SAME LOCATION.

C. MINIMUM CONDUIT SIZE IS 3/4".

RE ALARM CONTROL PANEL
INUCIATOR PANEL
ANSPONDER PANEL
ISTED SHIELDED PAIR
RE ALARM INITIATING DEVICE CIRCUIT, 2-#14 AWG
RE ALARM REMOTE ANNUCIATOR CIRCUIT
RE ALARM MAPNET CHANNEL CIRCUIT, T.S.P. #18 AWG
RE ALARM REMOTE MICROPHONE CIRCUIT
RE ALARM MAPNET CHANNEL POWER CIRCUIT, 2-#14 AWG
RE ALARM COMMUNICATION CIRCUIT, T.S.P. #18 AWG
RE ALARM NOTIFICATION APPLIANCE CIRCUIT FOR SPEAKERS, T